TAMIL NADU FIRE AND RESCUE SERVICES LICENCE

(Under section 13 of the Tamil Nadu Fire Service Act 1985 and

Tamil Nadu Fire Service Rule 1990 - Appendix-III)

District Office,

Fire and Rescue Service,

Tiruvallur District.

Licence No: 35062/RFL/NMSB/2026

Dated: 10/02/2026

RENEWAL OF FIRE LICENSE

Ref: (1) Letter no:368268 from the M/s. T.J.S. Polytechnic College , Dated: 06/02/2026

****

The Fire License is hereby **renewed** under section 13 of the Tamil Nadu Fire and Rescue Service Act 1985 for **TO RUN COLLAGE** in the name of **M/S. T.J.S POLYTECHNIC COLLEGE, NO.99/01, TO 100/15, T.J.S. NAGAR PERUVOYAL VILLAGE, NEAR KAVARIPETTAI, GUMMIDIPOONDI TALUK, THIRUVALLUR DISTRICT.** Consisting of Ground Floor + Two Floors only with the Height of 10.17 Meters and total built-up area in 910.00 Sq.mt within the jurisdiction of Gummidipoondi based on the inspection was done by the Station Officer Gummidipoondi on 07/02/2026. Subject to the condition noted thereon and such other conditions as may be prescribed. This licence is valid for **THREE YEARS** from 10/02/2026 **to** 09/02/2029 and should be renewed on 10/02/2029.

CONDITIONS

1. All firefighting equipment should always be kept in good working condition at all times and it should be as per the NBC 2016 part -IV maintained well and working in good condition. The trained personnel should always be available to operate the systems in case of any emergency.
2. Fire extinguishers should be installed and maintained as per IS 2190:2010
3. All Staff should be trained in preliminary firefighting as per G.O.No:713 Home (Police-17), Dated: 17.08.2005 with Fire and Rescue Services Department.
4. Mock drill should be periodically conducted.
5. Any addition and/or alteration of a permanent or temporary structure should be intimated to the Fire and Rescue Services Department.
6. Fire order / contingency plan / evacuation plan should be prepared and displayed in each floor at prominent places and Dos & Donts boards should be displayed.
7. Emergency fire exit, staircases and doors should not be obstructed.
8. Good housekeeping should be maintained and dumping of waste materials anywhere should be avoided.
9. All the electrical equipment, fitting, accessories and Wiring system should be maintained. As per IS 1646 : 1997 Code of Practice for Fire Safety of Building (General) Electrical Installation should be followed.

Signature valid

Signed by: DISTRICT OFFICER THIRUVALLUR Tiruvallur, Northwestern Region - District Officer, Home Department
Date:10-Feb-2026 13:27:30

To:

M/S. T.J.S POLYTECHNIC COLLEGE,

NO.99/01, TO 100/15, T.J.S. NAGAR PERUVOYAL VILLAGE,

NEAR KAVARIPETTAI,

GUMMIDIPOONDI TALUK,

THIRUVALLUR DISTRICT.